
Warringtonfire Holmesfield Road Warrington United Kingdom T: +44 (0)1925 655116 W: www.warringtonfire.com



Class 0 Summary Report



Including Opinion Of Compliance With The Requirements For A Class 0 Surface As Defined In Paragraph A13(b) Of Approved Document B (Volumes 1 & 2), (2006 Edition) 'Fire Safety' To The Building Regulations 2000

A Report To: Avery Dennison Materials Belgium

Document Reference: 407729 & 407730

Date: 8th March 2019

Issue No.: 1

Page 1

Executive Summary

Objective

To assess the results of tests to BS 476:Part 6:1989+A1: 2009 and BS 476:Part 7:1997, obtained on specimens of the following product and to provide an opinion of compliance with the requirements for a Class 0 surface, as defined in Approved Document B to the Building Regulations 2000.

Generic Description	Product reference	Thickness	Weight per unit area or density	
Self-adhesive wall covering film adhered to an aluminium substrate	None assigned	3.18mm*	7.83kg/m ^{2*}	
Individual components used to manufacture composite:				
Self adhesive film	"JT 8500 WG-SPB"	90µm	130g/m²	
Substrate	"Aluminium"	3mm	2710kg/m³	
*determined by Warringtonfire				
Please see page 5 of this test report for the full description of the product tested				

Test Sponsor Avery Dennison Materials Belgium, Bld. Kennedy Z.I. Zone B, 7060 – Soignies,

Belgium

Opinion: We consider the results of the tests to BS 476:Part 6:1989+A1: 2009 and BS

476:Part 7: 1997, demonstrate that the product, as tested, complies with the requirements for Class 0, as defined in paragraph A13(b) of Approved Document

B, `Fire Safety', to the Building Regulations 2000.

Date of Test 2nd, 11th and 15th February 2019

Signatories

Responsible Officer

T. Mort *

Senior Technical Officer

Authorised S. Deeming *

Business Unit Head

* For and on behalf of Warringtonfire.

Report Issued: 8th March 2019

This version of the report has been produced from a .pdf format electronic file that has been provided by Warringtonfire to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of Warringtonfire.

Document No.: 407729 & 407730 Page No.: 2 of 7

Author: T. Mort Issue Date: 8th March 2019

CONTENTS	PAGE NO.
EXECUTIVE SUMMARY	2
SIGNATORIES	2
TEST DETAILS	4
DESCRIPTION OF TEST SPECIMENS	5
CLASSIFICATION	6
REVISION HISTORY	7

Document No.: 407729 & 407730 Page No.: 3 of 7

Author: T. Mort Issue Date: 8th March 2019

Test Details

Terms Of Reference

To assess the results of tests to BS 476:Part 6:1989+A1: 2009 and BS 476:Part 7:1997, obtained on specimens of a product and to provide an opinion of compliance with the requirements for a Class 0 surface, as defined in Approved Document B to the Building Regulations 2000.

Introduction

Specimens of a product have been tested in accordance with the test methods specified in BS 476: Part 6: 1989+A1: 2009 'Method of test for fire propagation for products' and BS 476: Part 7: 1997 'Method of test to determine the classification of the surface spread of flame of products'. The results of the tests are fully reported in the Warringtonfire test reports No's. 407729 and 407730.

This summary test report has been prepared at the request of the sponsor and relates the results of the tests to the requirements for a Class 0 surface of a material or composite product, as defined in paragraph A13(b) of Approved Document B, `Fire Safety', to the Building Regulations 2000.

This summary should be read in conjunction with, and not accepted as a substitute for, the Warringtonfire test reports No's. 407729 and 407730. Those test reports may include additional information which may be relevant to the assessment of the potential fire hazard of the product.

Face subjected to tests

The specimens were mounted in the test positions such that the film face was exposed to the heating conditions of the tests.

Results of test

The following results were obtained for the specimens, which were tested.

BS	47	6:	P	art	6:
198	9+	A 1	į	20	09

Fire propagation index, I	=	0.0
subindex, i ₁	=	0.0
subindex, i ₂	=	0.0
subindex, i ₃	=	0.0

BS 476: Part 7: 1997

Class 1 surface spread of flame

The test results relate only to the behaviour of the test specimens of the product under the particular conditions of the test, they are not intended to be the sole criterion for assessing the potential hazard of the product in use.

Document No.: 407729 & 407730 Page No.: 4 of 7

Author: T. Mort Issue Date: 8th March 2019

Description of Test Specimens

The description of the specimens given below has been prepared from information provided by the sponsor of the test. This information has not been independently verified by Warringtonfire. All values quoted are nominal, unless tolerances are given.

General description		otion	Self-adhesive wall covering film adhered to an aluminium substrate	
Thickness of overall composite		verall composite	3.18mm (determined by Warringtonfire)	
		area of overall composite	7.83kg/m² (determined by Warringtonfire)	
	Product refer		"JT 8500 WG-SPB"	
	Name of mar		AVERY DENNISON MATERIALS BELGIUM	
	Overall thick		90µm	
		nt per unit area	130g/m²	
	Overall weigh	Generic type	Polyvinyl chloride (PVC) film	
		Product reference	"White Gloss"	
		Name of manufacturer	See Note 1 below	
	Film	Thickness	See Note 1 below	
		Density	See Note 1 below	
Ε		Colour reference	"White"	
Self-adhesive film		Flame retardant details	See Note 2 below	
<u>.</u>		Generic type	See Note 3 below	
Sec		Product reference	See Note 3 below	
호	Vinyl	Name of manufacturer	See Note 3 below	
1 🚆		Thickness	See Note 3 below	
S	-	Density	See Note 3 below	
		Colour reference	See Note 3 below	
		Flame retardant details	See Note 3 below	
		Generic type	Acrylic	
		Product reference	Semi-Permanent Black"	
		Name of manufacturer	See Note 1 below	
	Adhesive	Application rate / thickness	See Note 1 below	
		Application method	Pressure sensitive	
		Flame retardant details	See Note 2 below	
		Curing process	See Note 1 below	
		Product reference	"Aluminium"	
		Generic type	Aluminium	
	Substrate	Name of supplier	S.A. Joinery	
	Cabbilate	Overall thickness	3mm	
		Density	2710kg/m³	
Flame retardant details			The substrate is inherently flame retardant	
Br	ief descriptior	n of manufacturing process	PVC film coated on one side with acrylic adhesive	

- Note 1. The sponsor of the test was unwilling to provide this information.
- Note 2. The sponsor of the test has confirmed that no flame retardant additives were utilised in the production of the component.
- Note 3. The sponsor of the test was unable to provide this information.

Document No.: 407729 & 407730 Page No.: 5 of 7

Author: T. Mort Issue Date: 8th March 2019

Classification

Opinion

We consider the results of the tests detailed above demonstrate that the product, as tested, complies with the requirements for Class 0, as defined in paragraph A13(b) of Approved Document B, `Fire Safety', to the Building Regulations 2000.

Validity of opinion

This opinion is based on the requirements of the Building Regulations at the date of this report. If the Building Regulations are revised or amended in any way subsequent to that date, care must be taken to ensure that this opinion is not invalidated by those revisions or amendments.

The opinion has been formulated on the assumption that the specimens are representative of the product in practice. Warringtonfire was not involved in any sampling or selection procedures which would confirm this or in any audit testing which would provide confidence in the consistency of the product in the tests.

This report may only be reproduced in full. Extracts or abridgements shall not be published without permission of Warringtonfire.

Document No.: 407729 & 407730 Page No.: 6 of 7

Author: T. Mort Issue Date: 8th March 2019

Revision History

Issue No:	Re-issue Date:
Revised By:	Approved By:
Reason for Revision:	

Issue No :	Re-issue Date:
Revised By:	Approved By:
Reason for Revision:	

Document No.: 407729 & 407730 Page No.: 7 of 3

Author: T. Mort Issue Date: 8th March 2019